

CITY OF LEE'S SUMMIT CODES ADMINISTRATION 220 SE GREEN ST. P.O.BOX 1600

PHONE: 816-969-1200

FAX:

816-969-1201

Inspection Summary

Permit #: PRCOM20100137, Building Permit - Commercial Address: 1255 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Outcome: Date:

Underground John Borns Not Ready Monday, July 11, 2011

Electrical Inspection

- Commercial

Partial Correction

1 E300.5 Underground 1. PARTIAL -UNDER DRIVEWAY/FRONT STREET ONLY-FROM

Installations OUT SIDE CURB TO CURB

1" TO SUMP PUMP

1" TO MONUMENT SIGN

Corrective Action Required

2 MISC 7/11/11 REQUEST FOR INSPECTION OF SITE ELECTRICAL

BURIED CONDUIT: CONDUIT NOT COMPLETELY LAID IN TRENCH

Comments: