

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20231857  
Address: 4809 NE JAMESTOWN DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Driveway Inspection</b>	Anthony Agcopra	Partial	Wednesday, September 20, 2023

Informational:	
1      Misc	9-29-23 A.A DW is formed, depth is correct, aggregate is compacted. Will need to maintain 2% slope through driveway but conditions can change, approved to pour

**Comments:**