

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20231491
Address: 1524 NE PARK SPRINGS TER, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Anthony Agcopra	Passed	Wednesday, September 20, 2023

Informational:

1	Misc	9-12-23 A.A DW is formed, aggregate is compacted. Will need to maintain 2% slope through driveway but conditions can change, approved to pour
		9-20-23 DW is poured. Slopes are in compliance. Forms are pulled . Passed

Comments: