

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20226005
Address: 1901 SW RIVER RUN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Mitchell Schwarz	Failed	Wednesday, September 20, 2023

Corrective Action Required:

1 Misc

- Provide viewing for exterior nailing
- provide fastening schedule for breezeway sheathing stapled
- fire block throughout
- provide solid blocking for future grab bars in bathrooms
- install and vent bath fans
- missing stud in family changing room
- provide ufer ground bonding to main point of disconnect
- secure SE cable within 12" of panel
- derate SE cable running through attic
- no gas line to inspect

Comments: