

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20231621
Address: 2763 SW 12TH TER, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Driveway Inspection	Anthony Agcopra	Partial	Wednesday, September 20, 2023

Informational:	
1 Misc	9-20-23 A.A, DW is formed. Aggregate is compacted and depth is in compliance. Contractor was told to make sure they keep the 2% through approach. Approved to pour

Comments: