

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20225681  
Address: 2405 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Electrical Service Inspection</b>	Mitchell Schwarz	Failed	Thursday, September 21, 2023

Corrective Action Required:

1	Misc	-Connect the GEC to the middle grounded bus bar. -remove the ufer ground connection at the sub panel -remove the bonding screw from the sub panel
---	------	---

**Comments:**