

OPTIONAL ALTERNATE DETAIL 2

September 21, 2023

Joe Frogge
Plans Examiner – City of Lee's Summit
Joe.Frogge@cityofls.net


PROJECT:
NLV - Townhomes

LOCATION:
451 Southwest Longview Blvd
Lee's Summit, Missouri

PERMIT NUMBER:
PRCOMCOM20230057

Re: 5/8" Securock Firecode X inlieu of 5/8" Sheetrock Type X

To the best of the Architect's professional knowledge the aforementioned project, USG Securock Firecode X panels of 5/8" thickness meet or exceed the qualifications of the specified 5/8" Sheetrock Type X Per ASTM E84 and E136 to be used in protection of the rim boards at each floor line within demising walls separating the townhome units – per the attached detail from A003 and product cutsheet for Securock.


Jeff Windmeyer
Clockwork