

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20215208
Address: 209 NW AMBERSHAM DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Alex Fischer	Failed	Friday, September 22, 2023

Corrective Action Required:

2	Misc	-Loose cover at GFCI front porch -Missing security screws at back deck door per Chapter 7 of the LS City code -Missing self closing hinges at door to garage -Label non-GFCI in garage -Address hanging smoke detector in basement storage area -Missing security screws at back door per Chapter 7 of the LS City code -Missing splash blocks at down spouts
---	------	---

Comments: