

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20226232  
Address: 120 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Underslab Plumbing Inspection - Commercial</b>	Robb Popp	Partial	Friday, September 22, 2023

Corrective Action Required:

1	THE FOLLOWING AREAS ARE APPROVED	From North to South: Column line 0.0 to 1 -VISUAL ONLY-COMplete WATER COLUMN TEST
---	----------------------------------	--------------------------------------------------------------------------------------

**Comments:**