

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20231766
Address: 2751 SW 11TH TER, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Friday, September 22, 2023

Corrective Action Required:

- | | | |
|---|------|---|
| 1 | Misc | <ul style="list-style-type: none">- Provide hanger for triple LVL at entry/ gathering room- Protect sec in bedroom owners closet- Secure sst piping within 12" of appliance- Fire block top plate of second floor laundry- Nail off exterior corner of closet in bedroom 3- Nail exterior corner in bedroom 4- Fire block a/c chase off bedroom 3- Nail off corner north west in bedroom 2- Provide Egress window- Center plate under I beam next to Egress window- Anchor steel columns at basement stairs |
|---|------|---|

Comments: