

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20232261
Address: 1528 SW SUGAR TREE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Residential	Mitchell Schwarz	Failed	Monday, September 25, 2023

Corrective Action Required:

1	Misc	-Spark rings required for kitchen outlets -arc fault protection for basement outlets per E3901.16 of the 2018 IRC
---	------	--

Comments: