

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20232379

Address: 2070 NW LOWENSTEIN DR, Unit:IR, LEES SUMMIT, MO 640812070 NW LOWENSTEIN DR, Unit:A,  
LEES SUMMIT, MO 640812070 NW LOWENSTEIN DR, Unit:B, LEES SUMMIT, MO  
640812070 NW LOWENSTEIN DR, Unit:C, LEES SUMMIT, MO 640812060 NW  
LOWENSTEIN DR, LEES SUMMIT, MO 640812070 NW LOWENSTEIN DR, LEES SUMMIT,  
MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Commercial</b>	Robb Popp	Partial	Monday, September 25, 2023

Corrective Action Required:

1	Misc	-Demising wall ok to cover
		-STRAP TOP PLATES LAPPED LESS THAN 48"
		-FIRE CAULK ALL TOP PLATE PENETRATIONS
		-PROVIDE TRUSS PLANS AND LAYOUT FOR INSPECTION

Comments: