

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20213816

Address: 3712 SW WALSH DR, LEES SUMMIT, MO 640823714 SW WALSH DR, LEES SUMMIT, MO 640823716  
SW WALSH DR, LEES SUMMIT, MO 640823710 SW WALSH DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Driveway Inspection</b>	Anthony Agcopra	Passed	Monday, September 25, 2023

Informational:

1 Misc

9-11-23 A.A DW is formed, aggregate is compacted. Will need to maintain 2% slope through driveway but conditions can change, approved to pour  
9-18-23 A.A DW is poured. Slopes are in compliance. Cannot pass until forms are pulled  
9-25-23 A.A forms pulled . Passed

**Comments:**