

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20231815
Address: 2614 SW RIVER TRAIL RD, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pool Final - Residential	Mitchell Schwarz	Failed	Monday, September 25, 2023

Corrective Action Required:

1 Misc

- Gates to be self closing and latching
- Underground gas line not inspected uncover for inspection and needs pressure test performed
- paint gas line.
- identify water bond
- electrical panel working space and clearances not met. See Figure E3405.1 of 2018 IRC.

Comments: