

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20223648
Address: 2767 SW 11TH TER, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sidewalk Inspection	Anthony Agcopra	Passed	Monday, September 25, 2023

Informational:

1	Misc	6-1-23 DP. SW was formed, aggregate compacted, cross slopes in compliance but conditions can change. Approved to pour.
		9-18-23 SW is poured . Frames are pulled. Slopes are in compliance. 2 panels are chipped . Will need to be replaced .
		9-25-23 A.A, both panels replaced . and are in compliance . Passed

Comments: