

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20223032
Address: 2111 SW RED BARN LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Tuesday, September 26, 2023

Corrective Action Required:

1	Misc	-address pending pier inspection -address suspended slab not inspected -identify sewer tracer wire cap -water meter to be 14"-18" from top of meter to top of well lid ring -garage entry door to be self closing and latching -smoke detector in master dead battery
---	------	--

Comments: