

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20221409  
Address: 2022 SW RED BARN LN, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Mitchell Schwarz	Failed	Friday, September 22, 2023

Corrective Action Required:

1	Misc	-sod - Paint exterior gas piping - sewer trace wire to grade - Obtain an issued lawn irrigation permit
---	------	-----------------------------------------------------------------------------------------------------------------

**Comments:**