

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20232009

Address: 2141 SW OSAGE DR, LEES SUMMIT, MO 640822139 SW OSAGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Failed	Tuesday, September 26, 2023

Corrective Action Required:

2	Misc	2141 and 2139 - Final grading and sod - Sidewalk and driveway inspection pending - Provide splash pads - Obtain irrigation permit if installing
		2139 - No functioning water closet - Tighten and break off set screw on anti siphon device at spigot on main water supply

Comments: