



September 28, 2022

Pat Cochran Concrete

Re: 2111 SW Red Barn Lane
Lot 80 Retreat at Hook Farms
Lee's Summit, MO
PRRES20223032

Apex Engineers, Inc. observed the deck piers holes and suspended front stoop for the house under construction at the above referenced address.

The front stoop will be suspended. The forms and reinforcing steel were found to be clean, well aligned, properly supported, and in general compliance with the approved prints.

Two (2) 24" diameter piers were drilled a minimum of 3'-0" in depth to competent soil bearing and found to be in compliance with the on-site approved foundation print.

Our firm recommends approval of the deck piers and stoop for the placement of concrete. This report does not constitute approval by the enforcing jurisdiction.

LIMITATIONS

The recommendations and conclusions given in this report are based on the observed conditions at the time of this site visit. The scope of our services was only to observe the installation of the slab formwork and reinforcing steel.

Please call if Apex Engineers, Inc. can be of further assistance.

Best Regards,
Apex Engineers, Inc.


Stephen Fitch
Inspections Manager

Clayton J. Hess
Principal

