

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20221051
Address: 3218 SW ENOCH ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Failed	Wednesday, September 27, 2023

Corrective Action Required:

1 Misc

GFCI protection for outlets under kitchen island sink
-lock out for breaker for all hardwired appliances in kitchen
-address post to beam connection at deck. Beams resting on posts not connected

Comments: