

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20231955
Address: 2125 SW RUTHERFORD DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Kyle Beard	Failed	Wednesday, September 27, 2023

Corrective Action Required:

1	Miscellaneous Correction	-SD cable in master bathroom needs a BOCA plate installed -Supply vents through the basement floor to the main level need to be sealed -Seal top and bottom plate penetrations at stairwell to garage
---	-----------------------------	---

Comments: