

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20231621  
Address: 2763 SW 12TH TER, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Driveway Inspection</b>	Anthony Agcopra	Passed	Wednesday, September 27, 2023

Informational:

1	Misc	9-20-23 A.A, DW is formed. Aggregate is compacted and depth is in compliance. Contractor was told to make sure they keep the 2% through approach. Approved to pour 9-27-23 A.A, DW is poured and frames are pulled. Slopes are in compliance . Passed
---	------	---

**Comments:**