

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20233310

Address: 3745 SW CLAYTON PL, LEES SUMMIT, MO 640823743 SW CLAYTON PL, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Kyle Beard	Failed	Thursday, September 28, 2023

Informational:

1	Miscellaneous Correction	Garage portal CSPF passed for both units. This is a partial all rough only.
---	--------------------------	---

Comments: