

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20231105  
Address: 800 NW WARD RD, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Water Line - Hydrostatic Test</b>	John Jackson	Passed	Thursday, September 28, 2023

Informational:  
1 Misc 09/28/23 Thursday MJM (ESS-Matt)  
Contractor is combining fire and domestic water line together testing all water lines for 2 hour @ 200psi. (Passed)

**Comments:**