

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20233779
Address: 3542 SE CORBIN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Residential	Kyle Beard	Failed	Thursday, September 28, 2023

Corrective Action Required:

1	Miscellaneous Correction	- UFER is not excess-able - Rec room in basement must be on an AFCI breaker - access hole under stairs in basement must have a hatch
---	--------------------------	--

Comments: