

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20222783
Address: 1231 NW MAIN ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Sanitary Sewer - Vacuum	John Jackson	Passed	Thursday, September 21, 2023

Informational:
1 Misc 09/21/23 Thursday MJM (Central Plumbing-Steve)
Vacuum test passed of 3:30minutes @9 psi. for private manhole on the
Westside of proposed building #3.

Comments: