CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20220570

Address: 1100 NW MAIN ST, Unit:FP, LEES SUMMIT, MO 640861100 NW MAIN ST, Unit:IR, LEES SUMMIT, MO 640861100 NW MAIN ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Robb Popp	Failed	Thursday, September 28, 2023
Corrective Action Required:			
1 Misc	 -Complete corrections for all other departments -Complete rated assembly -Complete gate and generator installation -Paint all exterior metallic gas lines -Identify separate gas services -Provide plaque for separately located disconnects per NEC 230.72 -Have engineer evaluate SW corner of building visibly "settling" and complete any prescribed corrections 		

Comments: