

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20224767
Address: 1100 NW MAIN ST, Unit:D, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Robb Popp	Failed	Thursday, September 28, 2023

Corrective Action Required:

1	Misc	-Complete corrections for all other departments -Install restroom grab bars per code -Secure all mc within 12" of boxes or equipment -Install all cover plates -Support sprinkler pipes vertically per code at tenant spaces -Complete installation of sinks in restrooms -Correct gap at receptacles at women's restroom and break room -Mirrors to be max 40' aff to reflective surface -Remove plastic above ceiling in IT room -Protect receptacles at charging stations within 6' of water -Complete rated assembly inspections -Complete egress paths at west exit
---	------	---

**OK TO STOCK AND TRAIN ONLY

Comments: