

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20225745  
Address: 3219 SW ENOCH ST, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Sidewalk Inspection</b>	Anthony Agcopra	Passed	Monday, October 02, 2023

Informational:  
1 Misc 9-26-23 Sw in rear of house is framed and aggregate is compacted. Slope is in compliance . Approved to pour.  
10-2-23 Dustin A, SW is poured. Slopes are in compliance. Forms are pulled.  
Passed

**Comments:**