

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20233310

Address: 3745 SW CLAYTON PL, LEES SUMMIT, MO 640823743 SW CLAYTON PL, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                      | Inspector: | Outcome: | Date:                     |
|----------------------------------|------------|----------|---------------------------|
| <b>Rated Assembly Inspection</b> | Kyle Beard | Failed   | Tuesday, October 03, 2023 |

Corrective Action Required:

|   |                             |                                                                      |
|---|-----------------------------|----------------------------------------------------------------------|
| 1 | Miscellaneous<br>Correction | Fire decking is cut through within 4 feet of the rated assembly wall |
|---|-----------------------------|----------------------------------------------------------------------|

**Comments:**