

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20233616

Address: 2202 SW OSAGE DR, LEES SUMMIT, MO 640822204 SW OSAGE DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control	Kyle Beard	Partial	Tuesday, October 03, 2023

Corrective Action Required:

1	Miscellaneous Correction	Full erosion control is not installed. Full erosion control is required until occupancy of the building 08/16/2023. KBEARD
---	--------------------------	--

Informational:

3	Miscellaneous Correction	Erosion control is in place and needs to be maintained until full occupancy
---	--------------------------	---

Comments: