

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20224162
Address: 3221 SW PERGOLA PARK DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Water - Material Verification	Ryan Heckman	Passed	Tuesday, October 03, 2023

Informational:

1 Misc

Winwater delivered:

8" C900 pipe

6" C900 pipe

Zinc stamped epoxy coated fittings(tees, bends, solid sleeves)

Epoxy coated 6" and 8" gate valves

Kennedy K81D fire hydrants

Blue tracer wire and locator tape 10/27/22 ES

Comments: