



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20110420, Building Permit - Commercial
Address: 910 NW BLUE PKWY, Unit:P, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Miscellaneous Inspection	John Borns	Partial	Friday, July 15, 2011

Partial Correction
1 MISC

LIGHTED SIGN ELEMENTS BEAR UL LABELS ON TOP.
MANUFACTURER STATED TO BE AD-ART, WHICH APPEARS ON
UL DATABASE AS CERTIFIED SIGN MANUFACTURER.

Comments: