

David P. Ainsworth, P.E.
1200 NW Hearn Ave, Blue Springs, MO 64015
Cell Phone: 816-682-2093
Email: dainsworth@chelepis.com

October 3, 2023

Mr. Bill Wilson
M. L. Crose Foundations
4512 N Allison Rd
Sibley, MO 64088

Re: 2206 SW Red Barn Ln
Lee's Summit, MO
Hook Farms Lot 56
Damaged Concrete @ Garage Door Inspection

Dear Mr. Wilson:

On October 3, 2023, I inspected the damaged concrete at the garage door opening at the above referenced property. When backfilling the garage area the equipment operator hit the lower right hand corner and broke a chunk of concrete off.

To repair this damage you should saw cut the sections out and pin #4 rebar into existing form and pour back. This repair will provide adequate support for the damaged corner.

Cordially,



David P. Ainsworth, P.E.

