

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20232824
Address: 910 NW BLUE PKWY, Unit:G, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Robb Popp	Failed	Wednesday, October 04, 2023

Corrective Action Required:

1	Misc	-Complete corrections for LSFD -Label electrical panel -Tighten loose receptacle at north wall -Move grab bars in restrooms to be code compliant -Missing escutcheon near south windows -Complete hvac in hallway **OK TO STOCK AND TRAIN ONLY-DO NOT OCCUPY
---	------	--

Comments: