CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20231716

Address: 2012 SW HOLDBROOKS DR, LEES SUMMIT, MO 640822014 SW HOLDBROOKS DR, LEES SUMMIT,

MO 640822016 SW HOLDBROOKS DR, LEES SUMMIT, MO 640822018 SW HOLDBROOKS

DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Rated Assembly Inspection Kyle Beard Failed Thursday, October 05,

2023

Informational:

1 Miscellaneous Rated assembly screw pattern in unit 2018 passed. Ok to cover

Correction

Corrective Action Required:

2 Miscellaneous -Fire rated assembly sheet rock in basement of 2014 under stairs is not

Correction completed

- Piece of fire rated assembly sheet rock is broken in 2014 garage and is to

large to just fill it with mud

- Gaps in fire rated assembly sheet rock larger than 1/4 of an inch must be

replaced with closer gaps in unit 2014

Comments: