

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20230813
Address: 3511 SW MARKET ST, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	Kyle Beard	Passed	Thursday, October 05, 2023
Informational:			
1 Miscellaneous Correction	Sweeps for secondary lines at transformer base were installed located on the east side of the lot passed inspection. This is a partial pass only		
Informational:			
2 Miscellaneous Correction	Secondary line at transformer to about 20 feet shy of the building passed for underground electrical. This is another partial pass only 07/14/2023. KBEARD		
Informational:			
3 Miscellaneous Correction	Secondary line is completed and passed for underground inspection. Light pole underground will be called in at a later date.		
Informational:			
4 Misc	Under ground electrical for the exterior garden area passed. This is a partial pass only. 08/07/2023 KBEARD		
Informational:			
5 Miscellaneous Correction	This is a partial pass for under ground electric for parking lot light poles only. This is only a partial pass. 08/08/2022 KBEARD		
Informational:			
6 Miscellaneous Correction	All under ground electrical has been completed		

Comments: