

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20213806  
Address: 3809 SW MARYVILLE PL, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Piers/Caissons Inspection - Residential</b>	Kyle Beard	Failed	Thursday, October 05, 2023

Corrective Action Required:

1	Miscellaneous Correction	Stairs and corners of deck post piers passed. The original post deck pier has never passed an inspection and could not be verified for depth or width. Original post carries the deck and roof load. This is a partial pass only.
---	--------------------------	-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

**Comments:**