

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20226005  
Address: 1901 SW RIVER RUN DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Water Service Inspection</b>	Patrick Schonfeldt	Partial	Friday, October 06, 2023

Informational:

1 Misc

9-13-23 PS Partial inspection on pex service line from building to meter well location. OK to cover partial inspected.

9-13-23 PS Water service approved

Do not cover main - Service line at 1828 SW River Run was struck off main excavating for pool house service line and is damaged. This will need to be addressed with new copper line bored across street before cover

10-6-23 PS Per Brent with water issues for service line at 1828 SW River Run have been resolved

**Comments:**