CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #:PRCOM20226232Address:120 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Foundation Inspection - Commercial	Robb Popp	Partial	Friday, October 06, 2023
Corrective Action Required:			
1 Misc	**Foundation stem walls: Complete		
	**Elevator: -Stem walls -1st level walls		
	**Stairwell		
	-1st level walls		
	**Columns -1st level columns comple -Canopy pilasters at CB -Columns on existing roof	te top: #s 1,2,3,8.9,10,11.15,16	5,17,18,19,20,21

Comments: