

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20231716

Address: 2012 SW HOLDBROOKS DR, LEES SUMMIT, MO 640822014 SW HOLDBROOKS DR, LEES SUMMIT,
MO 640822016 SW HOLDBROOKS DR, LEES SUMMIT, MO 640822018 SW HOLDBROOKS
DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Kyle Beard	Failed	Friday, October 06, 2023

Informational:

1	Miscellaneous Correction	Rated assembly screw pattern in unit 2018 passed. Ok to cover
---	--------------------------	---

Corrective Action Required:

2	Miscellaneous Correction	- Piece of fire rated assembly sheet rock is broken in 2014 garage and is to large to just fill it with mud - Gaps in fire rated assembly sheet rock larger than 1/4 of an inch must be replaced with closer gaps in unit 2014
---	--------------------------	--

Comments: