

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20234293
Address: 1220 NW MAIN ST, Unit:A, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	Robb Popp	Partial	Friday, October 06, 2023

Corrective Action Required:

1 Misc

***Demising wall framing ok

***Office area: provide Bocca plates at top and bottom track where dwv is less than 1.25" to face of framing

-OK TO ONE SIDE AND CLOSE NON PLUMBING WALLS

Comments: