

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20222785

Address: 1220 NW MAIN ST, Unit:IR, LEES SUMMIT, MO 640861220 NW MAIN ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection	Robb Popp	Failed	Tuesday, October 10, 2023

Corrective Action Required:

1	Misc	-Provide bonding bushing at HP disconnect -Provide documentation on 1600 amp adjustable breaker setting
---	------	--

Comments: