

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20225393  
Address: 801 SW M 150 HWY, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	Mitchell Schwarz	Partial	Wednesday, October 11, 2023

Corrective Action Required:

1	Misc	Second floor bath only. Install bath vents
---	------	--

Corrective Action Required:

2	Misc	First floor Inspected. -dayroom border of drop ceiling -bathrooms -conference room border of drop ceiling -captain office border of drop ceiling -covered patio on W side -east patio/entrance -water lines in inspected areas to be insulated 10/11/23 Mitchell Schwarz
---	------	---

**Comments:**