

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816) 969-1200 FAX (816) 969-1201

# STOP WORK ORDER

**ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE  
PROSECUTED**

---

**Permit #:** PRRES20233664  
**Address:** 2206 SW RED BARN LN, LEES SUMMIT, MO 64082

---

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Mitchell Schwarz	Failed - Stop Work	Wednesday, October 11, 2023

Corrective Action Required  
1 Misc

No inspection performed  
Provide engineering for damaged foundation wall at garage.

Stop work issued  
-engineer letter needs to provide details on fix for foundation wall repair. Repair made and concrete poured without inspection.

**Comments:**