



## Midwest Distribution TI

### 20234293 – RACKING SUBMISSION

10.12.23

- 
- a. Racking 20' AFF, 5' top tier storage height = 25' total storage height AFF.
  - b. Each rack will have 4 or 5 shelves/tiers.
  - c. Bottom of lowest sprinkler head is 31' AFF, top of storage is 25' AFF = 6' clearance.
  - d. Typical isle is 5' between racks, with exception of area of wider isles. Wider isles will be 16'.
  - e. Commodity classification is 85, Snack Foods.
  - f. No product is banded or encapsulated.
  - g. No transverse or longitudinal flue spaces delineated.

---

If any additional information is needed in response to these correction items, please contact me.

**Greg Mitchem**

Forge Construction

Project Manager

[gmitchem@forgconstructionkc.com](mailto:gmitchem@forgconstructionkc.com)

913.529.9193