CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #:PRCOM20192646Address:3201 NW PARAGON PKWY, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	Robb Popp	Partial	Thursday, October 12, 2023
Corrective Action Required:			

 1
 Misc
 -Seal all gaps and penetrations through shaft layer with approved means at elevator shaft (2) locations at steel and at gap in East building future hvac shaft at bar joist

 -(3) future shafts approvded to cover

Comments: