

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRRES20233616

Address: 2202 SW OSAGE DR, LEES SUMMIT, MO 640822204 SW OSAGE DR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Kyle Beard	Not Ready	Friday, October 13, 2023

Corrective Action Required:

1	Miscellaneous Correction	This is a portal frame inspection only.  2204 Exterior NW corner single CS-PF portal frame is not nailed off.  2202 Passed
---	--------------------------	--

Corrective Action Required:

2	Miscellaneous Correction	Electrician was still working in both units in the basement. Insulation crew was working in 2202. 10/13/2023 KBEARD 9:30am
---	--------------------------	--

**Comments:**