## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #: PRCOM20225393 Address: 801 SW M 150 HWY, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Mitchell Schwarz	Failed	Friday, October 13, 2023
Corrective Action Required:	Cocord floor both only	Install bath years	
1 Misc Corrective Action Required:	Second floor bath only. Install bath vents		
2 Misc	First floor Inspected. -dayroom border of drop ceiling -bathrooms -conference room border of drop ceiling -captain office border of drop ceiling -covered patio on W side -east patio/entrance		
	-water lines in inspected areas to be insulated -secure MC within 12" of boxes -S most bathroom sprinkler to be completed -S most bathroom duct work completed 10/11/23 Mitchell Schwarz		

Comments: