

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20231016  
Address: 2075 NW OBRIEN RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Driveway Inspection</b>	Anthony Agcopra	Partial	Monday, October 16, 2023

Informational:

1	Misc	9-18-23 A.A DW is formed, aggregate is compacted. Will need to maintain 2% slope through driveway but conditions can change, approved to pour
		9-25-23 Dustin A, DW is poured. Cannot pass until forms are pulled
		10-9-23 Dustin A conditions have not changed
		10-16-23 Dustin A, Conditions have not changed

**Comments:**